

FIRE SAFETY MEASURES IN FIRE CRACKERS STORAGES

SELF APPRAISAL

Name and Address of the Fire Crackers Storages				
No of floors in the Premises				
*1	Whether the proposed hazardous occupancy is located away from human habitation? (Never be permitted in mixed occupancy.)	Yes	No	--
*2	Whether adequate Fire safety measures were adopted?	Yes	No	--
*3	Whether the required minimum number of two exits with the recommended width as per clause -8 of National Building Code of India – Part IV are maintained?	Yes	No	--
*4	Whether the required exit signs and emergency lighting source is provided in the escape routes?	Yes	No	--
*5	Whether the required escape route (Corridor) and Fire exit stair cases were separated with recommended rate Fire resistance doors?	Yes	No	--
*6	Whether all the required minimum Fire Fighting Installation as recommended in Table20 under clause 7-10-2 of National Building Code if India – Part IV are provided?	Yes	No	--
*7	Whether prior clearance was obtained before commencement of construction as regards to Fire Safety from the Director General of Fire & Emergency Services. Andhra Pradesh, Hyderabad?	Yes	No	--
*8	Whether the lifts were provided with solid doors with Fire resistance of at least on hour?	Yes	No	Not applicable
*9	Whether the exit from the lift lobby if located in the core of the building was provided through a self closing smoke stop of an hour Fire resistance?	Yes	No	Not applicable
*10	Whether all the provisions of A.P.Fire Service Act-1999 and Municipal Corporation building bye-Law are strictly implemented.	Yes	No	--
*11	Where open spaces around the hazardous occupancy premises are maintained as recommended in the National Building Code of India and Municipal building bye –laws with out any obstructions allowing free Movements of Fire Units?	Yes	No	--
*12	Whether the necessary awareness among the people about minimum safety measure and Do's and Don'ts in tune of Fire and methods to save their lives was created?	Yes	No	--
*13	Whether the number of Fire extinguishers are in accordance with the respective suggestions? (This Should be enforced strictly.)	Yes	No	--

14	Whether the Buildings and cellars were provided with ramps?	Yes	No	Not applicable
*15	Whether the width of the stair case is provided and maintained as per National Building Code of India – Part IV and Municipal Corporation Building bye – Laws?	Yes	No	--
*16	Whether the manufacturing / storing /Sale of Fire Crackers premise is far – away from residential and commercial area?	Yes	No	--
*17	Whether the godown and shops are located in an open area?	Yes	No	--
*18	Whether adequate fire fighting equipment viz., 5 kg., capacity dry chemical power extinguisher and Four Fire buckets filled with sand / water were provided and maintained at an easily accessible location are readily available in the fire cracker shop?	Yes	No	--
*19	Whether all the electrical installations and fittings were got inspected by authorized electrician?	Yes	No	--
*20	Whether the manufacturing /storing or sales shop of Fire Crackers are constructed with all non combustible and Fire resistance materials?	Yes	No	--

Signature of the Owner/
Management of Fire Crackers

Storages

with Designation and Office

Seal

Place:

Date

Standard referred:Govt.Memo.No.1020/L&O-II/A2002-2.Genl..Admn.(Law & Order II)
Department,dt.15-1-2003 accepting the recommendations of one man inquiry.

Committee and National Building Code, 1997.

*Note: The Fire Safety Measures indicated with star mark are mandatory.

PROFARMA

UNDERTAKING

THIS LETTERS OF UNDER TAKING is executed by-----
--

IN FAVOUR of the Director General, Fire and Emergency Services,
B.R.K.R.Governement Offices Complex, Tank bund Road, Hyderabd-500063.

1. We say that we are promoters and Developers/Builders of the Multi_Storeyed Building
at -----

2. We say that as stipulated by you we will provide all fire safety systems as per National Building code and Multi-Storeyed Building Regulations, 1981 in the above Multi-Storeyed Building and prepared the estimate of Rs. ----- towards the provision of all fire fighting systems and submit the estimate in original along with the General information and checklist on fire safety measures for approval.

3. We undertake to incur an expenditure of Rs. ----- for providing fire safety arrangements as per details furnished in the above estimate.

4. We undertake to lurrush Bank Guarantee for 15% of the total estimated cost of fore safety systems as above in favor of Director General of Fire Services. Obtained from any Nationalized Bank for period of 5 years guaranteeing to provide all fire fighting systems as per National Building Code and Maintain them in good working condition round the clock.

5. We agree that the above Bank Guarantee Can be invoked by Director of Fire Services at any time in the event of non-provision or non-maintenance of fire fighting systems in our Multi Storeyed Building as per National Building Code or in the event of non-compliance of any other fire safety measures suggested in the provisional No-Objection Certificate.

6. We also agree that the provisional No-Objection Certificate shall be issued by the Director General of Fire Services for the Construction of Multi Storeyed Building only after furnishing the above Bank Guarantee by us.

7. We say that as stipulated by you we will undertake to impart training to 40% of the occupants and employees working at Building in Fire Prevention and Fire Fighting at Andhra Pradesh Fire Serves State Training School, Vattinagulapally, Hyderabad with in 6 months from the date of occupation.

8. We undertake to maintained and keep the fire fighting equipment at Building-----

In good working condition at all times by regularly servicing and replacing the obsolete equipment

Place: Signature of the Builder/Promoter/Developer.

Date: Name:
Designation:
Address for Correspondence:
Contact Telephone Number: